



Office of Training
and Certification

New Jersey Division of Fire Safety

BASIC PRACTICAL SKILLS EXAMINATION REPORT

Skill sheet #

FF1-09

Certification title

Firefighter 1
FIRE GROUND OPERATIONS
SCBA PERFORM CONSERVATION OF AIR AND
EMERGENCY PROCEDURES.

Applicant Information

Candidate name

DFS ID #

Course #

Evaluation

Standard:
NFPA 1001, 2013 Edition
5-3.1

Task

Use of SCBA during emergency operation: perform conservation of air and emergency procedures. **Evaluator: Order critical**

Conditions and Outcome

Given personal protective clothing and SCBA the candidate, while operating in a simulated IDLH environment, shall be able to use controlled breathing techniques and perform emergency procedures in the event of SCBA failure. **The candidate will complete this task with a minimum of 7 items answered correctly.**

Number	Task Steps	First Test		Retest #1		Retest #2	
		Pass	Fail	Pass	Fail	Pass	Fail
	CONSERVATION OF AIR						
1	Demonstrate controlled breathing when instructed to (e.g., inhale through the nose, exhale through the mouth, and control rate of breathing)						
2	Demonstrate skip breathing when instructed to (e.g., take a regular breath and hold, take another breath, exhale, and repeat)						
	SCBA FAILURE						
3	Emergency procedures when air is not flowing into the face piece: Check that cylinder is fully open Close mainline, if present Open bypass slowly Close bypass after each breath Open bypass for next breath Exit hazardous area rapidly						
4	Emergency procedures when face piece is no longer intact: Breathe directly from low pressure hose or regulator Make tight seal around hose or regulator with mouth Breathe through mouth and exhale through nose Exit hazardous area rapidly						
	DEPLETION OF AIR SUPPLY						
5	Emergency procedures when out of air with no air re-supply available Activate pass device Establish filter breathing while staying as low as possible Exit hazardous area rapidly						

(continued on the next page)

FF1-09 USE SCBA DURING EMERGENCY OPERATIONS						Page 2	
Number	Task Steps	First Test		Retest #1		Retest 2	
		Pass	Fail	Pass	Fail	Pass	Fail
	PASS DEVICE USE						
9	Activate PASS device in alarm mode “panic button”						
Final Test Result for Entire Task							

Evaluator signature & comments, Test #1		Evaluator signature & comments, Retest #1		Evaluator signature & comments, Retest #2	
Evaluator signature	Date	Evaluator signature	Date	Evaluator signature	Date
Candidate signature & acknowledgement, Test #1		Candidate signature & acknowledgement, Retest #1		Candidate signature & acknowledgement, Retest #2	
By my signature below I acknowledge I have read and understood the evaluation results and evaluator comments		By my signature below I acknowledge I have read and understood the evaluation results and evaluator comments		By my signature below I acknowledge I have read and understood the evaluation results and evaluator comments	
Candidate signature	Date	Candidate signature	Date	Candidate signature	Date

Form DFS-SS-1 10/12

Approved by NJ SME Committee 10/23/2013.