



Office of Training
and Certification

New Jersey Division of Fire Safety

BASIC PRACTICAL SKILLS EXAMINATION REPORT

Skill sheet #

IFBI-08

Certification title

**Industrial Fire Brigade
Incipient Member**

Applicant Information

Candidate name

DFS ID #

Course #

Evaluation

Standard:
NFPA 1081, 4.1.2.4
2018 Edition

Task

The brigade member will demonstrate the ability to clean, inspect, and maintain equipment associated with industry.

Conditions and Outcome

The brigade member will use an industry standard SCBA to conduct an inspection, clean, and record the serviceability.

Number	Task Steps	First Test		Retest #1		Retest #2	
		Pass	Fail	Pass	Fail	Pass	Fail
1	Identify proper storage control by AHJ.						
2	Identify the agency / facility record keeping files.						
3	Identify daily, monthly, inspection records.						
4	Identify notification process for equipment failures and related inspection records.						
5	Inspect, clean and sanitize face mask.						
6	Inspect, clean restore harness straps.						
7	Inspect and record SCBA bottle condition and pressure.						
8	Inspect and record SCBA bottle hydro date.						
9	Return SCBA to full working order.						
10	Return apparatus to proper storage location per the AHJ.						
Final Test Result for Entire Task							

Evaluator signature & comments, Test #1		Evaluator signature & comments, Retest #1		Evaluator signature & comments, Retest #2	
Evaluator signature	Date	Evaluator signature	Date	Evaluator signature	Date
Candidate signature & acknowledgement, Test #1		Candidate signature & acknowledgement, Retest #1		Candidate signature & acknowledgement, Retest #1	
By my signature below I acknowledge I have read and understood the evaluation results and evaluator comments		By my signature below I acknowledge I have read and understood the evaluation results and evaluator comments		By my signature below I acknowledge I have read and understood the evaluation results and evaluator comments	
Candidate signature	Date	Candidate signature	Date	Candidate signature	Date

Form DFS-SS-1 10/12

APPROVED BY NJSME 07/22/2020